

Product Certification Schedule

Schedule No: 186/001/028

Licensee: RR KABEL LTD., PLOT NO 201, 202/1, 202/2, 203 & 327/3, KHANDA ROAD, VILLAGE WAGHODIA, WAGHODIA, VADODARA - 391 760, GUJARAT, INDIA

Factory: RR KABEL LTD., PLOT NO 201, 202/1, 202/2, 203 & 327/3, KHANDA ROAD, VILLAGE WAGHODIA, WAGHODIA, VADODARA - 391 760, GUJARAT, INDIA

Specification: BS 5467:2016 Incorporating Corrigendum No.1 Electric cables - Thermosetting insulated, armoured cables of rated voltages of 600/1000V and 1900/3300V for fixed installations - Specification.

Type of Cable: Table 4 - Single-core 600/1000V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 50sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Single-core. Sheath - Type 9. Insulation - GP8.

Origin Thread: Not applicable

Origin Mark: RR KABEL W or -MEW- or RET

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 03/07/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 23/06/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004