

## Product Certification Schedule

Schedule No: 186/001/018

Licensee: RR KABEL LTD., PLOT NO 201, 202/1, 202/2, 203 & 327/3, KHANDA ROAD, VILLAGE WAGHODIA, WAGHODIA, VADODARA - 391 760, GUJARAT, INDIA

Factory: RR KABEL LTD., PLOT NO 201, 202/1, 202/2, 203 & 327/3, KHANDA ROAD, VILLAGE WAGHODIA, WAGHODIA, VADODARA - 391 760, GUJARAT, INDIA

Specification: BS 6231:2006 Incorporating Corrigendum No.1 - Electric cables - Single core PVC insulated flexible cables of rated voltage 600/1000 V for switchgear and controlgear wiring

Type of Cable: PVC insulated flexible cable - Type CK

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 0.5sqmm to 240sqmm nominal cross-sectional area of conductors inclusive. Single-core. Insulation - TI3.


Origin Thread: Not applicable

Origin Mark: RR KABEL W or -MEW- or RET



Expiry Date: 03/07/2017

Signed for and on behalf of the British Approvals Service for Cables

 Date 17/06/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004