

Certificate of Product Approval

Certificate Number: 1834a

Issue: 01

RR Kabel Ltd

At & Post Village, Waghodia, Khanda Road
TAL: Waghodia
Dist: Vadodara - 391760
Gujarat
India

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Fire Survival Cable

Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)
EN 61034-2:2005+A2:2020
EN 60754-1:2014
EN 60332-1-2:2004+A11:2016
EN 60332-3-24:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha

Senior Certification Manager

7 February 2025

Date of Issue

7 February 2025

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1834a RR Kabel Ltd

Issue: 01

Product name						LPCB Ref. No.
Fire Survival Cable						1834a/01
Nominal csa of conductor (mm²) See note 1	Core Construction	BS 6387 See note 2	EN 61034-2	EN 60754-1	EN 60332-1-2	EN 60332-3-24
1.5	2,3,4,5,7,12,19,27 & 37	CWZ	>60%	<0.5% HCl	Compiles	Complies
2.5	2,3,4,5,7,12,19,27 & 37	CWZ	>60%	<0.5% HCl	Compiles	Complies
4.0	2,3,4,5,7,12,19,27 & 37	CWZ	>60%	<0.5% HCl	Compiles	Complies
6.0	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
10	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
16	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
25	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
35	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
50	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
70	2,3,4 & 5	CWZ	>60%	<0.5% HCl	Compiles	Complies
95	2,3 & 4	CWZ	>60%	<0.5% HCl	Compiles	Complies
120	2,3 & 4	CWZ	>60%	<0.5% HCl	Compiles	Complies

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha

Senior Certification Manager

7 February 2025

Date of Issue

7 February 2025

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1834a RR Kabel Ltd

Issue: 01

Product name						LPCB Ref. No.
Fire Survival Cable						1834a/01
Nominal csa of conductor (mm²) See note 1	Core Construction	BS 6387 See note 2	EN 61034-2	EN 60754-1	EN 60332-1-2	EN 60332-3-24
150	2,3 & 4	CWZ	>60%	<0.5% HCI	Compiles	Complies
185	2,3 & 4	CWZ	>60%	<0.5% HCI	Compiles	Complies
240	2,3 & 4	CWZ	>60%	<0.5% HCI	Compiles	Complies
300	2,3 & 4	CWZ	>60%	<0.5% HCI	Compiles	Complies
400	2,3 & 4	CWZ	>60%	<0.5% HCI	Compiles	Complies

Uo/U 600/1000V

Notes:

1. Stranded conductors only.
2. Cables with an overall diameter of greater than 20mm were tested according to Annex I of BS 7846.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha

Senior Certification Manager

7 February 2025

Date of Issue

7 February 2025

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



bre